

1445
24/6/14
Tele: 227584

REGISTERED POST A/D
Garrison Engineer (Maint)
Naval Air Station
Arakkonam - 631 006

8100/ 503 /E8

19 Jun 2014

M/s B Duraga Reddy Infrastructures Pvt Ltd
DNo 36-46-5/3, 2nd Floor
Annapoorna Complex, Urvasi Junction
Kancharapalem, Visakhapatnam-530 008

**CA NO : CE(NAVY)/VIZ/ARK/06 OF 2011-2012 : PROVISION OF ELECTRICAL
POWER FENCING AND CERATIN MISCELLANEOUS WORKS (B/R & E/M)
AT INS RAJALI ARAKKONAM**

Dear Sir (s),

1. References :-

- (a) This office letter No 8100/477/E8 dt 27 Feb 2014,
- (b) Your letter No BDR/ARAKKONAM/13-14/TUE dt 25 Mar 2014
- (c) Your letter No BDR/CROWNSOLAR/ARKNM/14-15/THU dt 24 Apr 2014.
- (d) This office letter No 8100/497/E8 dt 21 May 2014
- (e) This office letter No 8100/498/E8 dt 09 Jun 2014
- (f) Your letter No BDR/ARAKKONAM/14-15/TUE dt 09 Jun 2014

2. The work was certified as completed on Jul 2013 subject to rectification of certain defects and the defects have been listed in the completion certificate. In addition, certain other defects also developed after completion of the work and these were referred to you for rectifying the same. However, it is noticed that no rectification is being carried out at site.


3. Please note that almost 10 months are over now after completion of the work, but the power fencing could not be handed over to the users because of your fault in rectifying the defects notified to you and making the power fence functional. It is regretted to say that your performance in this regard is very poor.

4. Your attention is invited to clause 46 of IAFW-2249 General conditions of Contract, forming Part of the contract. In view of the above, you are again asked to take suitable action to get the rectification completed on war footing and make the power fencing system functional by 30 Jun 2014. Your dispute with M/s Crown Solar Power fencing or M/s NEMTEK is not a matter of concern for the same.

5. It has been committed by you in your above referred letter dated 09 Jun 2014 that many equipments/electronic devices and softwares incorporated in the subject work are not as per approved make and CA specifications, which resulted in non functioning of power fencing system. In view of above, please note that defects liability period shall commence only from the date the power fencing system is made functional by you and taken over by the users.

6. Please acknowledge receipt

Yours faithfully,


(CH Rao)
Maj
Garrison Engineer

Copy to :-

CE (N) Visakhapatnam - for info please
CWE (N) Chennai-09 - for info please
AGE B/R (P) I/AGE E/M - for info please
NAS Arakkonam